



Petition #:	2016-014	Review Number:	1
Petition Reviewer:	Brady Glover	Date Reviewed:	November 23, 2015
Phone Number:	704-391-5171	Email Address:	brady.glover@charlottenc.gov

Comments:

In relation to the parcels under review, Charlotte Water has water system availability via the existing 12-inch water main located along Carmel Road.

In relation to the parcels under review, Charlotte Water has sewer system availability via the existing 8-inch gravity sewer mains located on the northwest corner of parcel 211-411-13 and along Carmel Road.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.