



Petition #:	2016-016	Review Number:	1
Petition Reviewer:	Brady Glover	Date Reviewed:	November 23, 2015
Phone Number:	704-391-5171	Email Address:	brady.glover@charlottenc.gov

Comments:

In relation to the parcels under review, Charlotte Water has water system availability via the existing 6-inch water main located along East 26th Street and the 8-inch water main located along North Davidson Street.

In relation to the parcels under review, Charlotte Water has sewer system availability via the existing 8-inch gravity sewer mains located along East 26th Street and North Davidson Street. Additionally, an existing 12-inch sewer main is located parallel to the northwestern border of parcel 083-052-04 within the property lines.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.