



Petition #:	2016-017	Review Number:	1
Petition Reviewer:	Brady Glover	Date Reviewed:	December 11, 2015
Phone Number:	704-391-5171	Email Address:	brady.glover@charlottenc.gov

Comments:

In relation to the parcels under review, Charlotte Water has water system availability via the existing 6-inch water mains located along Marshall Place and Atherton Street. Additionally, an existing 2-inch water main is located from Atherton Street to parcel #121-076-16 along Euclid Avenue.

In relation to the parcels under review, Charlotte Water has sewer system availability via the existing 8-inch gravity sewer mains located along Atherton Street and Marshall Place.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.