



| | | | |
|---------------------------|--------------|-----------------------|------------------------------|
| Petition #: | 2016-019 | Review Number: | 1 |
| Petition Reviewer: | Brady Glover | Date Reviewed: | December 11, 2015 |
| Phone Number: | 704-391-5171 | Email Address: | brady.glover@charlottenc.gov |

Comments:

In relation to the parcels under review, Charlotte Water has water system availability via the existing 6-inch water mains located along Campus Street and Mill Road.

In relation to the parcels under review, Charlotte Water has sewer system availability via the existing 8-inch gravity sewer mains located along Campus Street, Mill Road, and Beatties Ford Road.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.