



<b>Petition #:</b>	2016-023	<b>Review Number:</b>	1
<b>Petition Reviewer:</b>	Brady Glover	<b>Date Reviewed:</b>	December 11, 2015
<b>Phone Number:</b>	704-391-5171	<b>Email Address:</b>	brady.glover@charlottenc.gov

**Comments:**

In relation to the parcel under review, Charlotte Water does not currently have water system availability. The developer should contact Charlotte Water's Installation & Development Services for information regarding development around water services for this parcel.

In relation to the parcel under review, Charlotte Water has sewer system availability via the existing 8-inch gravity sewer main located along Old Concord Road.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.