



Petition #:	2016-029	Review Number:	1
Petition Reviewer:	Brady Glover	Date Reviewed:	December 15, 2015
Phone Number:	704-391-5171	Email Address:	brady.glover@charlottenc.gov

Comments:

In relation to the parcels under review, Charlotte Water has water system availability via the existing 6-inch water mains located along Belmont Avenue and along North Brevard Street from the southwest to Belmont Avenue. Additionally, an existing 8-inch water main is located along East 16th Street, and a 12-inch water main is located along North Brevard Street and Parkwood Avenue.

In relation to the parcels under review, Charlotte Water has sewer system availability via the existing 8-inch gravity sewer mains located along East 16th Street, Belmont Avenue, Parkwood Avenue, and North Brevard Street, a 10-inch gravity sewer main located along North Brevard Street, and 12-inch gravity sewer mains located at the southwestern section of parcel 081-042-02 and through the northern and eastern section of parcel 081-062-15.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.