



<b>Petition #:</b>	2016-033	<b>Review Number:</b>	1
<b>Petition Reviewer:</b>	Brady Glover	<b>Date Reviewed:</b>	January 13, 2016
<b>Phone Number:</b>	704-391-5171	<b>Email Address:</b>	brady.glover@charlottenc.gov

**Comments:**

In relation to the parcel under review, Charlotte Water has water system availability via existing 6-inch water mains located along West 5<sup>th</sup> Street and Frazier Avenue.

In relation to the parcel under review, Charlotte Water has sewer system availability via existing 8-inch gravity sewer mains located along West 5<sup>th</sup> Street and Frazier Avenue. It should be noted that a section of the 8-inch sewer main is located within the boundary of the parcel at the northwest corner of the property.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.