



Petition #:	2016-035	Review Number:	1
Petition Reviewer:	Brady Glover	Date Reviewed:	January 13, 2016
Phone Number:	704-391-5171	Email Address:	brady.glover@charlottenc.gov

Comments:

In relation to the parcel under review, Charlotte Water has water system availability via the existing 12-inch water main located along North Tryon Street.

Charlotte Water currently does not have sewer system availability for the parcel under review. The closest available sewer main is approximately 1,500 feet northwest of the property on JW Clay Boulevard. The applicant should contact Charlotte Water's New Services at (704) 432-5801 for more information regarding accessibility to sewer system connections.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.

