



<b>Petition #:</b>	2016-038	<b>Review Number:</b>	1
<b>Petition Reviewer:</b>	Brady Glover	<b>Date Reviewed:</b>	January 13, 2016
<b>Phone Number:</b>	704-391-5171	<b>Email Address:</b>	brady.glover@charlottenc.gov

**Comments:**

In relation to the parcels under review, Charlotte Water has water system availability via the existing 8-inch water main located along Old Rozzelles Ferry Road.

Charlotte Water currently does not have sewer system availability for the parcels under review. The closest available sewer main is approximately 150 feet east of parcel 031-222-56 on Rozzelles Ferry Road. The applicant should contact Charlotte Water's New Services at (704) 432-5801 for more information regarding accessibility to sewer system connections.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.