



To: Tammie Keplinger, CMPC
From: Ashley Botkin, Engineering Land Development
Date: April 14th, 2016
Rezoning Petition #: 2016-040 Revised

Detailed construction plans for the proposed site development are to be submitted for review and approval to the City of Charlotte's Land Development Division **after land entitlement (approved rezoning)**. Staff from City Land Development, Charlotte DOT, and the Planning Department review and inspect development projects in order to ensure compliance with pertinent City ordinances and standards. Please note Building Permit applications can be submitted concurrently to Mecklenburg County Code Enforcement and permit issuance will be conditioned upon the City of Charlotte's plan approval as required. Additional information may be found at our website: <http://development.charmeck.org>.

The Petitioner acknowledges that in addition to the conditions set forth in this petition and in the Zoning Ordinance, development requirements imposed by other City ordinances, construction standards, and design manuals do exist, are not waived or modified by the rezoning approval, and may be applicable to the proposed development. These development requirements include the regulation of streets, sidewalks, trees, and storm water. Where the conditions set forth in this Rezoning Plan conflict with other City development requirements, the stricter condition or requirement shall apply.

Comments for this rezoning:

Tom Ferguson – No comments

Laurie Dukes – Revise 2. Optional Provisions q. and III. Providence Road Design Guidelines c. Planting strip is required to be a minimum of 8 feet wide per tree ordinance. If providing a planting strip less than the minimum requirement of 8 feet, development is required to utilize suspended sidewalk (per 40.03) wherever the planting strip is less than 8 feet wide. This will allow tree roots to grow under sidewalk and occupy a total planting area of 8 feet wide.

Jay Wilson –