



Petition #:	2016-046	Review Number:	1
Petition Reviewer:	Brady Glover	Date Reviewed:	February 12, 2016
Phone Number:	704-391-5171	Email Address:	brady.glover@charlottenc.gov

Comments:

In relation to the parcels under review, Charlotte Water has water system availability for the rezoning boundary via an existing 12-inch water main located along Central Avenue, an existing 2-inch water main located along Heath Court, and an 8-inch water main located along Hawthorne Lane.

In relation to the parcels under review, Charlotte Water has sewer system availability for the rezoning boundary via existing 8-inch gravity sewer mains located along Central Avenue, Heath Court, and Hawthorne Lane.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.