



Petition #:	2016-049	Review Number:	1
Petition Reviewer:	Brady Glover	Date Reviewed:	February 19, 2016
Phone Number:	704-391-5171	Email Address:	brady.glover@charlottenc.gov

Comments:

In relation to the parcels under review, Charlotte Water currently has water system availability for the rezoning boundary via an existing 12-inch water main located along West Pointe Drive.

In relation to the parcels under review, Charlotte Water currently has sewer system availability for the rezoning boundary via an existing 8-inch sewer main located along West Pointe Drive.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.