



Petition #:	2016-050	Review Number:	1
Petition Reviewer:	Brady Glover	Date Reviewed:	February 19, 2016
Phone Number:	704-391-5171	Email Address:	brady.glover@charlottenc.gov

Comments:

In relation to the parcel under review, Charlotte Water currently does not have water system availability via a water distribution main. The closest water distribution main is approximately 900 feet south of the property at the intersection of Old Concord Road and Suther Road. The applicant should contact Charlotte Water's New Services at (704) 432-5801 for more information regarding accessibility to water system connections.

In relation to the parcel under review, Charlotte Water currently has sewer system availability for the rezoning boundary via an existing 8-inch sewer main located along Old Concord Road.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.