



Petition #:	2016-052	Review Number:	1
Petition Reviewer:	Brady Glover	Date Reviewed:	February 19, 2016
Phone Number:	704-391-5171	Email Address:	brady.glover@charlottenc.gov

Comments:

In relation to the parcel under review, Charlotte Water currently has water system availability via an existing 8-inch water main located along Keeter Drive.

In relation to the parcel under review, Charlotte Water currently has sewer system availability for the rezoning boundary via an existing 8-inch sewer main located along Keeter Drive along the northern border within the property.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.