



<b>Petition #:</b>	2016-053	<b>Review Number:</b>	1
<b>Petition Reviewer:</b>	Brady Glover	<b>Date Reviewed:</b>	February 19, 2016
<b>Phone Number:</b>	704-391-5171	<b>Email Address:</b>	brady.glover@charlottenc.gov

**Comments:**

In relation to the parcel under review, Charlotte Water currently has water system availability via an existing 12-inch water main located along Reames Road.

In relation to the parcel under review, Charlotte Water currently has sewer system availability via an existing 8-inch sewer main located within the property boundary approximately 120 feet north of Brookline Ridge Drive.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.