



Petition #:	2016-055	Review Number:	1
Petition Reviewer:	Brady Glover	Date Reviewed:	February 19, 2016
Phone Number:	704-391-5171	Email Address:	brady.glover@charlottenc.gov

Comments:

In relation to the parcel under review, Charlotte Water currently has water system availability for the rezoning boundary via an existing 12-inch water main located along Robert Helms Road. It should be noted that the existing 12-inch water main is currently available along the northeastern border of the property.

Charlotte Water does not currently have sewer system availability for the parcel under review. The closest sewer main is approximately 150 feet west of the southwest corner of the property on Prosperity Crossing Drive. The applicant should contact Charlotte Water's New Services at (704) 432-5801 for more information regarding accessibility to sewer system connections.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.