



Petition #:	2016-059	Review Number:	1
Petition Reviewer:	Brady Glover	Date Reviewed:	March 16, 2016
Phone Number:	704-391-5171	Email Address:	brady.glover@charlottenc.gov

Comments:

In relation to the parcel under review, Charlotte Water currently has water system availability via an existing 12-inch water main located along West Boulevard and an existing 6-inch water main located within the northwestern corner of the property.

In relation to the parcel under review, Charlotte Water currently has sewer system availability via existing 8-inch sewer mains located within the property and along West Boulevard.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.