



Petition #:	2016-061	Review Number:	1
Petition Reviewer:	Brady Glover	Date Reviewed:	March 16, 2016
Phone Number:	704-391-5171	Email Address:	brady.glover@charlottenc.gov

Comments:

In relation to the parcels under review, Charlotte Water currently has water system availability via an existing 8-inch water main located along Wilora Lake Road and an existing 2-inch water main located along Palmer Drive.

In relation to the parcels under review, Charlotte Water currently has sewer system availability via existing 8-inch sewer mains located along Wilora Lake Road, Palmer Road, and within the southern and eastern sections of the area under review.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.