



<b>Petition #:</b>	2016-062	<b>Review Number:</b>	1
<b>Petition Reviewer:</b>	Brady Glover	<b>Date Reviewed:</b>	April 12, 2016
<b>Phone Number:</b>	704-391-5171	<b>Email Address:</b>	brady.glover@charlottenc.gov

**Comments:**

In relation to the parcel under review, Charlotte Water has water system availability for the rezoning boundary via an existing 16-inch water main located along The Plaza.

Charlotte Water does not currently have sewer system availability for the parcel under review. The closest sewer main is approximately 260 feet east of the southeast corner of the property on The Plaza. The applicant should contact Charlotte Water's New Services at (704) 432-5801 for more information regarding accessibility to the water and sewer systems connections.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.