



<b>Petition #:</b>	2016-062	<b>Review Number:</b>	1
<b>Petition Reviewer:</b>	Brady Glover	<b>Date Reviewed:</b>	March 16, 2016
<b>Phone Number:</b>	704-391-5171	<b>Email Address:</b>	brady.glover@charlottenc.gov

**Comments:**

Charlotte Water does not currently have water or sewer system availability via water distribution mains or sewer mains for the parcels under review. The closest water distribution main is approximately 500 feet west of the southwest corner of the property at the intersection of The Plaza and East WT Harris Boulevard. The closest sewer main is approximately 260 feet east of the southeast corner of the property on The Plaza. The applicant should contact Charlotte Water's New Services at (704) 432-5801 for more information regarding accessibility to the water and sewer systems connections.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.