



Petition #:	2016-064	Review Number:	1
Petition Reviewer:	Brady Glover	Date Reviewed:	March 18, 2016
Phone Number:	704-391-5171	Email Address:	brady.glover@charlottenc.gov

Comments:

In relation to the parcels under review, Charlotte Water currently has water distribution system availability via an existing 8-inch water main located near the intersection of Four Mile Creek Road and Ballantyne Commons Parkway.

Charlotte Water does not currently have sewer system availability for the parcels under review. The closest sewer main is approximately 250 feet northwest of the western corner of parcel 229-144-01 on Sir Francis Drake Drive. The applicant should contact Charlotte Water's New Services at (704) 432-5801 for more information regarding accessibility to sewer system connections.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.