



Petition #:	2016-065	Review Number:	1
Petition Reviewer:	Brady Glover	Date Reviewed:	March 18, 2016
Phone Number:	704-391-5171	Email Address:	brady.glover@charlottenc.gov

Comments:

In relation to the parcels under review, Charlotte Water currently has water distribution system availability via an existing 8-inch water main located along Little Rock Road and an existing 12-inch water main located at the intersection of Little Rock Road and Wilkinson Boulevard.

In relation to the parcels under review, Charlotte Water currently has sewer system availability via an existing 8-inch sewer main located approximately 100 feet south of the southwestern corner of the properties on Wilkinson Boulevard.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.