



Petition #:	2016-066	Review Number:	1
Petition Reviewer:	Brady Glover	Date Reviewed:	March 18, 2016
Phone Number:	704-391-5171	Email Address:	brady.glover@charlottenc.gov

Comments:

In relation to the parcel under review, Charlotte Water currently has water system availability via existing 8-inch water mains located along Rexford Road and Roxborough Road.

In relation to the parcel under review, Charlotte Water currently has sewer system availability via existing 8- and 10-inch sewer mains located along Roxborough Road.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.