



Petition #:	2016-068	Review Number:	1
Petition Reviewer:	Brady Glover	Date Reviewed:	March 18, 2016
Phone Number:	704-391-5171	Email Address:	brady.glover@charlottenc.gov

Comments:

In relation to the parcel under review, Charlotte Water currently has water system availability via existing 6-inch water mains located along Templeton Avenue, South Caldwell Street, and Lexington Avenue.

In relation to the parcel under review, Charlotte Water currently has sewer system availability via existing 8-inch sewer mains located along Templeton Avenue, South Caldwell Street, and Lexington Avenue.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.