



<b>Petition #:</b>	2016-069	<b>Review Number:</b>	1
<b>Petition Reviewer:</b>	Brady Glover	<b>Date Reviewed:</b>	March 18, 2016
<b>Phone Number:</b>	704-391-5171	<b>Email Address:</b>	brady.glover@charlottenc.gov

**Comments:**

In relation to the parcels under review, Charlotte Water currently has water system availability via existing 6-inch water mains located along Belmont Avenue and North Caldwell Street.

In relation to the parcels under review, Charlotte Water currently has sewer system availability via an existing 8-inch sewer main located along Belmont Avenue.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.