



Petition #:	2016-073	Review Number:	1
Petition Reviewer:	Alan H. Gaines	Date Reviewed:	April 6, 2016
Phone Number:	704-391-4689	Email Address:	againes@ci.charlotte.nc.us

Comments:

In relation to the parcel under review, Charlotte Water has water system availability for the rezoning boundary via an existing 8-inch water distribution main located along N. Davidson St.

In relation to the parcel under review, Charlotte Water has sewer system availability for the rezoning boundary via an existing 8-inch gravity sewer main located along N. Davidson St.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.