



To: Tammie Keplinger, CMPC
From: Ashley Botkin, Engineering Land Development
Date: June 15, 2016
Rezoning Petition #: 2016-082 Revised

Detailed construction plans for the proposed site development are to be submitted for review and approval to the City of Charlotte's Land Development Division **after land entitlement (approved rezoning)**. Staff from City Land Development, Charlotte DOT, and the Planning Department review and inspect development projects in order to ensure compliance with pertinent City ordinances and standards. Please note Building Permit applications can be submitted concurrently to Mecklenburg County Code Enforcement and permit issuance will be conditioned upon the City of Charlotte's plan approval as required. Additional information may be found at our website:

<http://development.charmeck.org>.

The Petitioner acknowledges that in addition to the conditions set forth in this petition and in the Zoning Ordinance, development requirements imposed by other City ordinances, construction standards, and design manuals do exist, are not waived or modified by the rezoning approval, and may be applicable to the proposed development. These development requirements include the regulation of streets, sidewalks, trees, and storm water. Where the conditions set forth in this Rezoning Plan conflict with other City development requirements, the stricter condition or requirement shall apply.

Comments for this rezoning:

Tom Ferguson – No comments

Laurie Dukes – Development of the site shall comply with the requirements of the City of Charlotte Tree Ordinance. Regarding 5.b. i: as site is located in a wedge, all tree save areas are to be undisturbed. Any debris removal in tree save areas must be accomplished by hand; no mechanical equipment permitted in tree save areas. Pursuant to the Tree Ordinance Guidelines, any alterations to the tree save area must be accomplished without mechanized equipment and made of organic, environmentally friendly materials, unless approved otherwise by the City. Coordinate all work in tree save areas with Urban Forestry.

Trees greater than two (2) inches diameter as measured 4.5' above ground and in the street right of way are protected by law; authorization for their removal is to be coordinated through the City Arborist office.

Jay Wilson –