



To: Tammie Keplinger, CMPC
From: Ashley Botkin, Engineering Land Development
Date: June 15, 2016
Rezoning Petition #: 2016-083 Revised

Detailed construction plans for the proposed site development are to be submitted for review and approval to the City of Charlotte's Land Development Division **after land entitlement (approved rezoning)**. Staff from City Land Development, Charlotte DOT, and the Planning Department review and inspect development projects in order to ensure compliance with pertinent City ordinances and standards. Please note Building Permit applications can be submitted concurrently to Mecklenburg County Code Enforcement and permit issuance will be conditioned upon the City of Charlotte's plan approval as required. Additional information may be found at our website:

<http://development.charmeck.org>.

The Petitioner acknowledges that in addition to the conditions set forth in this petition and in the Zoning Ordinance, development requirements imposed by other City ordinances, construction standards, and design manuals do exist, are not waived or modified by the rezoning approval, and may be applicable to the proposed development. These development requirements include the regulation of streets, sidewalks, trees, and storm water. Where the conditions set forth in this Rezoning Plan conflict with other City development requirements, the stricter condition or requirement shall apply.

Comments for this rezoning:

Tom Ferguson – No comments

Laurie Dukes – Development of the site shall comply with the requirements of the City of Charlotte Tree Ordinance. Project is located in a Wedge therefore the 15% tree save is required to be on site; no grading or tree removal permitted in tree save areas. No structure will be allowed within ten (10) feet of the tree save area. All tree save to be a minimum of 30 feet wide. Tree save (COS) as depicted on the rezoning does not appear to meet the tree save requirements.

Revise site development data to include 15% required tree save and not 10% as this is a commercial project not a single family project.

Trees greater than two (2) inches diameter as measured 4.5' above ground and in the street right of way are protected by law; authorization for their removal is to be coordinated through the City Arborist office

Jay Wilson –