



<b>Petition #:</b>	2016-089	<b>Review Number:</b>	1
<b>Petition Reviewer:</b>	Alan H. Gaines	<b>Date Reviewed:</b>	May 6, 2016
<b>Phone Number:</b>	704-391-4689	<b>Email Address:</b>	againes@ci.charlotte.nc.us

**Comments:**

In relation to the parcel under review, Charlotte Water has water system availability for the rezoning boundary via an existing 12-inch water distribution main located along DeArmon Road and an Existing 6-inch water distribution main located along Ridgeline Lane.

In relation to the parcel under review, Charlotte Water has sewer system availability for the rezoning boundary via an existing 8-inch gravity sewer main located in the western portion of the rezoning boundary and along DeArmon Road. There is also system availability via an existing 8-inch gravity sewer main located along Ridgeline Lane.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.