



Charlotte Storm Water
600 East Fourth Street
Charlotte, N C 28202-2844
OFFICE: 704 . 336 . RAIN
FAX: 704 . 336 . 6586

Rezoning Petition Review

To: Tammie Keplinger, CMPC

From: Doug Lozner

Date of Review: May 26, 2016 *(Revised September 14, 2016)*

Rezoning Petition #: 16-89

Existing Zoning: R-3

Proposed Zoning: INST (CD)

Location of Property: Approximately 4.35 acres located on the south side of DeArmon Road, between Mineral Ridge Way and Hampton Place Drive.

Recommendations Concerning Storm Water: Flooding and surface water quality impacts associated with impervious surfaces on this site are being addressed through compliance with the Post-Construction Stormwater Ordinance.

Please show and label potential 50' Undisturbed Post Construction Stormwater Ordinance buffer on the site plan and adjust construction limits to comply with buffer requirements OR submit documentation as specified in the Post Construction Stormwater Ordinance confirming no perennial or intermittent streams exist on the site.

Recommendations Due to revisions: *No additional recommendations are needed at this time.*