



Petition #:	2016-092	Review Number:	1
Petition Reviewer:	Alan H. Gaines	Date Reviewed:	May 9, 2016
Phone Number:	704-391-4689	Email Address:	againes@ci.charlotte.nc.us

Comments:

In relation to parcel 04113193 under review, Charlotte Water has water system availability for the rezoning boundary via an existing 8-inch water distribution main located along Meadow Knoll Drive and an existing 12-inch water distribution main located along Cindy Lane. In relation to parcels 04115612 and 04115613 under review, Charlotte Water has water system availability for the rezoning boundary via an existing 12-inch water distribution main located along Statesville Road.

In relation to parcel 04113193 under review, Charlotte Water has sewer system availability for the rezoning boundary via an existing 8-inch gravity sewer main located along Meadow Knoll Drive. In relation to parcels 04115612 and 04115613 under review, Charlotte Water has sewer system availability for the rezoning boundary via an existing 8-inch gravity sewer main located along Statesville Road.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.