



Petition #:	2016-104	Review Number:	1
Petition Reviewer:	Alan H. Gaines	Date Reviewed:	May 27, 2016
Phone Number:	704-391-4689	Email Address:	againes@ci.charlotte.nc.us

Comments:

In relation to the parcels under review, Charlotte Water has water system availability for the rezoning boundary via existing 8-inch water distribution mains located along West Arrowwood Road and Nations Ford Road.

In relation to the parcels under review, Charlotte Water has sewer system availability for the rezoning boundary via an existing 8-inch gravity sewer main located along West Arrowwood Road. There is also sewer system availability via an 8-inch gravity sewer main located in the southern portion of the rezoning boundary in parcel 203-18-902.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.