



Petition #:	2016-105	Review Number:	1
Petition Reviewer:	Alan H. Gaines	Date Reviewed:	May 27, 2016
Phone Number:	704-391-4689	Email Address:	againes@ci.charlotte.nc.us

Comments:

In relation to the parcel under review, Charlotte Water has water system availability for the rezoning boundary via an existing 12-inch water distribution main located along Queens Road and an existing 8-inch water distribution main located along Baxter Street.

In relation to the parcel under review, Charlotte Water has sewer system availability for the rezoning boundary via an existing 12-inch gravity sewer main located along Baxter Street and an existing 8-inch gravity sewer main located along Queens Road.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.