



Petition #:	2016-125	Review Number:	1
Petition Reviewer:	Alan H. Gaines	Date Reviewed:	August 2, 2016
Phone Number:	704-391-4689	Email Address:	againes@ci.charlotte.nc.us

Comments:

In relation to the parcel under review, Charlotte Water currently does not have water system availability via a water distribution main. The closest water distribution main is approximately 300 feet East of the property at the intersection of Tuckaseegee Road and Forestbrook Drive. The applicant should contact Charlotte Water's New Services at (704) 432-5801 for more information regarding accessibility to water system connections.

In relation to the parcels under review, Charlotte Water has sewer system availability for the rezoning boundary existing 8-inch gravity sewer mains located along Tuckaseegee Road and Mulberry Church Road.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.