

Charlotte Fire Department Comments for Rezor

Petitions: 2016-132 to 2016-139

Hearing Month: November

Reviewed By: Ashley Riggins

Review Date: 7-Sep-16

Petition Number	Petitioners Name
2016-132	RICHTER DEVELOPMENT, LLC
2016-133	K & H DEVELOPMENT, INC
2016-134	CAPROCK, LLC
2016-135	DAVID MEYER JR.-QUICKTRIP CORP
2016-136	GATEWAY COMMUNITIES NC, LLC
2016-137	KYLE SHORT
2016-138	SOUTHMINSTER, INC
2016-139	CHARTER PROPERTIES, INC

ning Petitions

Comments:
No on street parking on roads less than 26' clear width. See Charlottefire.org for other requirements.
NO COMMENTS,
No on street parking on roads less than 26' clear width. See Charlottefire.org for other requirements.
NO COMMENTS.
No on street parking on roads less than 26' clear width. See Charlottefire.org for other requirements.
NO COMMENTS.
No on street parking on roads less than 26' clear width. See Charlottefire.org for other requirements.
No on street parking on roads less than 26' clear width. See Charlottefire.org for other requirements.