



Petition #:	2016-141	Review Number:	1
Petition Reviewer:	Alan H. Gaines	Date Reviewed:	October 6, 2016
Phone Number:	704-391-4689	Email Address:	againes@ci.charlotte.nc.us

Comments:

In relation to the parcels under review, Charlotte Water has water system availability for the rezoning boundary via an existing 12-inch water distribution main located along East Independence Boulevard and an existing 8-inch water distribution main located along Wallace Road.

In relation to the parcels under review, Charlotte Water has water system availability for the rezoning boundary via existing 8-inch gravity sewer mains located along Wallace Road and East Independence Boulevard.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.