



<b>Petition #:</b>	2016-144	<b>Review Number:</b>	1
<b>Petition Reviewer:</b>	Alan H. Gaines	<b>Date Reviewed:</b>	October 6, 2016
<b>Phone Number:</b>	704-391-4689	<b>Email Address:</b>	againes@ci.charlotte.nc.us

**Comments:**

In relation to the parcels under review, Charlotte Water has water system availability for the rezoning boundary via an existing 6-inch water distribution main located along East 22<sup>nd</sup> Street and existing 8-inch water distribution mains located along East 21<sup>st</sup> Street and North Davidson Street. There is also a 2-inch water distribution main located along East 21<sup>st</sup> Street.

In relation to the parcels under review, Charlotte Water has water system availability for the rezoning boundary via existing 8-inch gravity sewer mains located along East 22<sup>nd</sup> Street, East 21<sup>st</sup> Street, and North Davidson Street.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.