



Petition #:	2017-003	Review Number:	1
Petition Reviewer:	Alan H. Gaines	Date Reviewed:	October 27, 2016
Phone Number:	704-391-4689	Email Address:	againes@ci.charlotte.nc.us

Comments:

In relation to the parcel under review, Charlotte Water has water system availability for the rezoning boundary via an existing 2-inch water distribution main located along Carter Avenue and an existing 6-inch water distribution main located along Woodward Avenue.

In relation to the parcel under review, Charlotte Water has sanitary sewer system availability for the rezoning boundary via existing 8-inch gravity sewer mains located along Carter Avenue, Woodward Avenue, and through parcel 079-042-04.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.