



| | | | |
|---------------------------|----------------|-----------------------|----------------------------|
| Petition #: | 2017-007 | Review Number: | 1 |
| Petition Reviewer: | Alan H. Gaines | Date Reviewed: | October 27, 2016 |
| Phone Number: | 704-391-4689 | Email Address: | againes@ci.charlotte.nc.us |

Comments:

In relation to the parcels under review, Charlotte Water has water system availability for the rezoning boundary via an existing 12-inch water distribution main located North Tryon Street.

In relation to the parcels under review, Charlotte Water has sanitary sewer system availability for the rezoning boundary via existing 8-inch gravity sewer mains located in the Western portion of Parcel 089-201-01 and North Tryon Street.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.