



To: Tammie Keplinger, CMPC  
From: Ashley Botkin, Engineering Land Development  
Date: January 31, 2017  
Rezoning Petition #: 2017-018 Revised

Detailed construction plans for the proposed site development are to be submitted for review and approval to the City of Charlotte's Land Development Division **after land entitlement (approved rezoning)**. Staff from City Land Development, Charlotte DOT, and the Planning Department review and inspect development projects in order to ensure compliance with pertinent City ordinances and standards. Please note Building Permit applications can be submitted concurrently to Mecklenburg County Code Enforcement and permit issuance will be conditioned upon the City of Charlotte's plan approval as required. Additional information may be found at our website: <http://development.charmeck.org>.

The Petitioner acknowledges that in addition to the conditions set forth in this petition and in the Zoning Ordinance, development requirements imposed by other City ordinances, construction standards, and design manuals do exist, are not waived or modified by the rezoning approval, and may be applicable to the proposed development. These development requirements include the regulation of streets, sidewalks, trees, and storm water. Where the conditions set forth in this Rezoning Plan conflict with other City development requirements, the stricter condition or requirement shall apply.

**Comments for this rezoning:**

Tom Ferguson (Engineering) – Please show and label required stream buffers on the site and adjust construction/development limits as necessary to comply with stream buffer requirements.

Peter Grisewood (Urban Forestry) – Add note: The site will comply with the Tree Ordinance.

The required 15% tree save area must contain existing, healthy trees. Easement areas cannot be accepted as tree save area. 15% gross area of the site = 0.89 acres tree save. Tree save area must be shown on rezoning plans.

Jay Wilson (Erosion Control) –