

# Rezoning Transportation Analysis

Petition Number: 2017-037

General Location Identifier: 173-162-78

**From: Kelsie Anderson, PE**  
[Kelsie.Anderson@charlottenc.gov](mailto:Kelsie.Anderson@charlottenc.gov)  
704-432-5492

Staff Reviewer: Kory Hedrick, PE, PMP  
Khedrick@charlottenc.gov  
704-432-6511

---

CDOT's review of this rezoning petition is intended to ensure consistency with the Transportation Action Plan (TAP) which seeks to ensure that the City's transportation network supports current and future land uses and includes streets that provide safe and comfortable mobility for motorists, pedestrians, bicyclists, and transit users.

This document is primarily for communication to Planning Department staff as part of the overall City staff analysis of the rezoning petition and includes an overall summary of the case from a transportation perspective, information on trip generation, and resolved or outstanding site plan concerns. Additional advisory information about the driveway permit process is provided for information only.

---

Based on our review of the petition, we offer the following information for your consideration.

## Transportation Summary

The site is located at the end of a local street that connects to a major thoroughfare at an unsignalized intersection. One of the main goals for CDOT during our review of this petition was to encourage a walkable environment for this community. The current site plan commits to an offsite sidewalk extension along Starmount Cove Lane to close a gap from the development to South Boulevard.

## General Description

The site is located at the end of Starmount Cove Ln., a local street that connects to South Blvd, a major thoroughfare at an unsignalized intersection. Rezoning 1999-027. The site is located in a wedge outside of Route 4 and is within the study area of the Arrowood Transit Station Area Plan.

## Trip Generation

Scenario	Land Use	Intensity	Trip Generation (vehicle trips/day)	Source
Existing Use	Vacant	N/A	0	Tax Record
Entitlement with Current Zoning	Single Family	43 dwellings	490	RZ 1999-027
Proposed Zoning	Townhomes	95 dwellings	620	Site Plan: 01-20-17

## Outstanding Issues

- ~~1. **Resolved Curb Line:** The proposed zoning district has a setback measured from an existing or proposed future curbline. The location of the future curbline on Starmount Cove Lane is the same as the existing curb line location.~~
- ~~2. **Resolved Traffic Study:** A Traffic Impact Study is not needed for the review of this petition.~~
- ~~3. **Resolved** CDOT requests that the petitioner provide sidewalk on Starmount Cove Ln connecting the proposed site to South Blvd.~~

# Rezoning Transportation Analysis

Petition Number: 2017-037

General Location Identifier: 173-162-78

- ~~4. **Resolved** The petitioner should revise the site plan to add a note specifying dedication and fee simple conveyance of all rights of way to the City before the site's first building certificate of occupancy is issued. CDOT requests right of way set at 2' behind back of sidewalk.~~
- ~~5. **Resolved** The petitioner should revise the site plan to add a note specifying all transportation improvements will be approved and constructed before the site's first building certificate of occupancy is issued or phased per the site's development plan.~~

## Advisory Information

The following are requirements of the developer that must be satisfied prior to driveway permit approval. We recommend that the petitioner reflect these on the rezoning plan as-appropriate.

1. According to the City of Charlotte's Driveway Regulations, CDOT has the authority to regulate/approve all private street/driveway and public street connections to the right-of-way of a street under the regulatory jurisdiction of the City of Charlotte.
2. Adequate sight triangles must be reserved at the existing/proposed street entrance(s). Two 35' x 35' sight triangles (and two 10' x 70' sight triangles on North Carolina Department of Transportation on NCDOT maintained streets) are required for the entrance(s) to meet requirements. All proposed trees, berms, walls, fences, and/or identification signs must not interfere with sight distance at the entrance(s). Such items should be identified on the site plan.
3. The proposed driveway connection(s) to public streets will require a driveway permit(s) to be submitted to CDOT (and the North Carolina Department of Transportation on NCDOT maintained streets) for review and approval. The exact driveway location(s) and type/width of the driveway(s) will be determined by CDOT during the driveway permit process. The locations of the driveway(s) shown on the site plan are subject to change in order to align with driveway(s) on the opposite side of the street and comply with City Driveway Regulations and the City Tree Ordinance.
4. All proposed commercial driveway connections to a future public street will require a driveway permit to be submitted to CDOT for review and approval.
5. Any fence or wall constructed along or adjacent to any sidewalk or street right-of-way requires a certificate issued by CDOT.
6. A Right-of-Way Encroachment Agreement is required for the installation of any non-standard item(s) (irrigation systems, decorative concrete pavement, brick pavers, etc.) within a proposed/existing City maintained street right-of-way by a private individual, group, business, or homeowner's/business association. An encroachment agreement must be approved by CDOT prior to the construction/installation of the non-standard item(s). Contact CDOT for additional information concerning cost, submittal, and liability insurance coverage requirements.

## Revision Log

Date	Description	By
02-16-17	First Review	KMH
03-20-17	Second Review	KMH