



<b>Petition #:</b>	2017-042	<b>Review Number:</b>	1
<b>Petition Reviewer:</b>	Alan H. Gaines	<b>Date Reviewed:</b>	February 8, 2017
<b>Phone Number:</b>	704-391-4689	<b>Email Address:</b>	againes@ci.charlotte.nc.us

**Comments:**

In relation to the parcels under review, Charlotte Water has water system availability for the rezoning boundary via existing 8-inch water distribution mains located along Olivia Catherine Way and Brandon Trail Drive. There is also availability via an existing 16-inch transmission main located along Rocky River Road.

In relation to the parcel under review, Charlotte Water has sewer system availability for the rezoning boundary via existing 10-inch gravity sewer main located along the Northern portion of parcel 105-361-01.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.