



<b>Petition #:</b>	2017-057	<b>Review Number:</b>	1
<b>Petition Reviewer:</b>	Alan H. Gaines	<b>Date Reviewed:</b>	March 17, 2017
<b>Phone Number:</b>	704-391-4689	<b>Email Address:</b>	againes@ci.charlotte.nc.us

**Comments:**

In relation to the parcel under review, Charlotte Water has water system availability via an existing 24-inch water transmission main along Pineville-Matthews Road and an existing 16-inch water transmission main located along Providence Road.

In relation to the parcels under review, Charlotte Water has sewer system availability for the rezoning boundary via existing 8-inch gravity sewer mains located along Pineville-Matthews Road, Providence Road, and Arboretum Shopping Center Drive.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.