



Petition #:	2017-068	Review Number:	1
Petition Reviewer:	Alan H. Gaines	Date Reviewed:	April 19, 2017
Phone Number:	704-391-4689	Email Address:	againes@ci.charlotte.nc.us

Comments:

In relation to the parcels under review, Charlotte Water has water system availability for the rezoning boundary via an existing 6-inch water main located along Faison Avenue.

In relation to the parcels under review, Charlotte Water has sewer system availability for the rezoning boundary via an existing 10-inch gravity sewer main located along the southern portions of parcels 083-06-821, 083-06-820, and 083-06-816.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.