



| | | | |
|---------------------------|----------------|-----------------------|----------------------------|
| Petition #: | 2017-069 | Review Number: | 1 |
| Petition Reviewer: | Alan H. Gaines | Date Reviewed: | April 19, 2017 |
| Phone Number: | 704-391-4689 | Email Address: | againes@ci.charlotte.nc.us |

Comments:

In relation to the parcels under review, Charlotte Water has water system availability for the rezoning boundary via an existing 8-inch water main located along Smithfield Church Road.

In relation to the parcels under review, Charlotte Water has sewer system availability for the rezoning boundary via an existing 8-inch gravity sewer main located along Smithfield Church Road and passing through parcels 209-22-222, 209-22-221, 209-22-224, and 209-22-299.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.