



Petition #:	2017-074	Review Number:	1
Petition Reviewer:	Alan H. Gaines	Date Reviewed:	April 19, 2017
Phone Number:	704-391-4689	Email Address:	againes@ci.charlotte.nc.us

Comments:

In relation to the parcel under review, Charlotte Water has water system availability for the rezoning boundary via existing 6-inch water distribution mains located along Drummond Avenue, Duncan Avenue, and the Plaza. There is also an existing 12-inch water distribution main located along the Plaza.

In relation to the parcel under review, Charlotte Water has sewer system availability for the rezoning boundary via existing 8-inch gravity sewer mains located along Drummond Avenue, Duncan Avenue, and The Plaza.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.