



<b>Petition #:</b>	2017-076	<b>Review Number:</b>	1
<b>Petition Reviewer:</b>	Alan H. Gaines	<b>Date Reviewed:</b>	April 19, 2017
<b>Phone Number:</b>	704-391-4689	<b>Email Address:</b>	againes@ci.charlotte.nc.us

**Comments:**

In relation to the parcel under review, Charlotte Water has water system availability for the rezoning boundary via an existing 16-inch water transmission main located along West Tyvola Road.

In relation to the parcel under review, Charlotte Water has sewer system availability for the rezoning boundary via an existing 54-inch gravity sewer main located along the western portion of parcel 143-13-301.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.