



| | | | |
|---------------------------|----------------|-----------------------|----------------------------|
| Petition #: | 2017-080 | Review Number: | 1 |
| Petition Reviewer: | Alan H. Gaines | Date Reviewed: | May 8, 2017 |
| Phone Number: | 704-391-4689 | Email Address: | againes@ci.charlotte.nc.us |

Comments:

In relation to the parcel under review, Charlotte Water has water system availability for the rezoning boundary via an existing 8-inch water distribution main located along Freedom Drive and an existing 12-inch water distribution main located along West Morehead Street.

In relation to the parcels under review, Charlotte Water has sewer system availability for the rezoning boundary via an existing 36-inch gravity sewer main, an existing 18-inch gravity sewer main, and an existing 12-inch gravity sewer main located within the rezoning boundary.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.