



<b>Petition #:</b>	2017-083	<b>Review Number:</b>	1
<b>Petition Reviewer:</b>	Alan H. Gaines	<b>Date Reviewed:</b>	May 8, 2017
<b>Phone Number:</b>	704-391-4689	<b>Email Address:</b>	againes@ci.charlotte.nc.us

**Comments:**

In relation to the parcels under review, Charlotte Water has water system availability for the rezoning boundary via an existing 6-inch water distribution main along Seigle Avenue, an existing 6-inch water distribution main located along Harrill Street, and existing 2-inch water distribution mains located along Van Every Street and Harrill Street.

In relation to the parcels under review, Charlotte Water has sewer system availability for the rezoning boundary via existing 8-inch gravity sewer mains located along Seigle Avenue and Harrill Street.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.