

## Charlotte Fire Department Comments for

**Petitions:** 2017-077 THRU 092  
**Hearing Month:** 18-May-17  
**Reviewed By:** S SULLIVAN  
**Review Date:** 26-Apr-17

**Petition Number:** **Petitioners Name:**

2017-077	TTR INVESTMENTS LLC
2017-078	COURTYNEY PARKER
2017-079	MCKINNEY HOLDINGS NC II LLC
2017-080	GRIFFIN EQUITITES LLC
2017-081	NINETY-EIGHT AND THREE QUARTERS
2017-082	GRIFFBREW INVESTMENTS, LLC
2017-083	CAPROCK, LLC
2017-084	CHEER ATHLETICS
2017-085	MARC EISENBEIS
2017-086	MECKLENBURG COUNTY PARK AND RECREATION
2017-087	REGIONS BANK
2017-088	TREVI PARTNERS, LLC1
2017-089	LAUREL STREET RESIDENTIAL
2017-090	CHILDRESS KLEIN PROPERTIES, INC
2017-091	COLONY AT PIPER GLEN
2017-092	DIRECT POWER, INC

## or Rezoning Petitions

### Comments:

No on street parking on roads less than 26' clear width. See Charlottefire.org for other requirements.
No on street parking on roads less than 26' clear width. See Charlottefire.org for other requirements.
No on street parking on roads less than 26' clear width. See Charlottefire.org for other requirements.
No on street parking on roads less than 26' clear width. See Charlottefire.org for other requirements.
No on street parking on roads less than 26' clear width. See Charlottefire.org for other requirements.
No on street parking on roads less than 26' clear width. See Charlottefire.org for other requirements.
No on street parking on roads less than 26' clear width. See Charlottefire.org for other requirements.
No on street parking on roads less than 26' clear width. See Charlottefire.org for other requirements.
No on street parking on roads less than 26' clear width. See Charlottefire.org for other requirements.
NO COMMENTS
NO ON STREET PARKING ON ROADS LESS THAN 26' CLEAR WIDTH. SEE CHARLOTTEFIRE.ORG FOR OTHER REQUIREMENTS.
NO ON STREET PARKING ON ROADS LESS THAN 26' CLEAR WIDTH. SEE CHARLOTTEFIRE.ORG FOR OTHER REQUIREMENTS.
NO ON STREET PARKING ON ROADS LESS THAN 26' CLEAR WIDTH. SEE CHARLOTTEFIRE.ORG FOR OTHER REQUIREMENTS.
NO ON STREET PARKING ON ROADS LESS THAN 26' CLEAR WIDTH. SEE CHARLOTTEFIRE.ORG FOR OTHER REQUIREMENTS.
NO ON STREET PARKING ON ROADS LESS THAN 26' CLEAR WIDTH. SEE CHARLOTTEFIRE.ORG FOR OTHER REQUIREMENTS.